



ELECTRICAL INSTALLATION REPORT

ConduitLab Sample Project

JOB SITE **123 Sample Way, Anytown, USA**

PREPARED FOR **ConduitLab Community Example**

PREPARED BY **ConduitLab™ – Electrical Reference Tool**

DATE **December 19, 2025**

RUN ID **CL-20251219-BFPV7d**

AMPACITY

53A

CONDUCTOR

**3 AWG Cu
THHN**

VOLTAGE DROP

2.51%

CONDUIT FILL

20.4%



Download ConduitLab

conduitlab.app

Pro

Summary Dashboard

RECOMMENDED CONDUCTOR

3 AWG

Copper • 90°C

VOLTAGE DROP

2.51%

5.22V drop • 202.8V at load

CONDUIT FILL

20.4%

1 1/4" EMT

JAM STATUS

OK

No jam risk

Parameter Summary

Load (A)	50 A	Voltage	208V
Material	Copper	Insulation	THHN (90°C)
Wire Size	3 AWG	Ambient Temp	35°C
Conductors	5	Continuous	Yes
Conduit	1 1/4" EMT	Circuit Length	250 ft
VD Method	AC Impedance (Exact)		Phase: Three-phase

Power Factor: 0.9

Inspector / Responsible Party Notes

Prepared By

License #

Date

Additional Notes

Ampacity Summary

FINAL AMPACITY

53 A

CONDUCTOR: 3 AWG Cu THHN

Calculation Breakdown

Factor	Value	Code Reference
Ambient Temperature	35°C → 68°C	—
Base Ampacity	115 A	Table 310.16
Rooftop Adder	+ 33°C	NEC 2020 310.15(B)(2)
Ambient Temp Correction	× 0.58	Based on NEC 2020 Table 310.15(B)(1)
Conductor Bundling	× 0.80	Based on NEC 2020 Table 310.15(C)(1)
Derated Ampacity	53.36 A	—
Terminal Rating	Not limited	110.14(C)
Final Ampacity	53 A	—

Detailed Ampacity Steps → See Appendix A

Voltage Drop & Conduit Fill

Voltage Drop Summary

VOLTAGE DROP RESULT

2.51 %

Drop Voltage: 5.22 V • Voltage at Load: 202.8 V

Parameter	Value
Load Current	50 A
Conductor	3 AWG Copper
Distance	250 ft
Method	AC Impedance (Tables 8 & 9)

Detailed VD Steps → See Appendix B

Conduit Fill Summary

CONDUIT FILL RESULT


20.4 %

Conduit: 1 1/4" EMT • Wires: 4

Parameter	Value
Total Wire Area	0.3048 in²
Conduit Area	1.4957 in²
NEC Max	40%

Detailed Fill Steps → See Appendix B

Conduit Visualization



Not to scale. Visualization is schematic and intended for conceptual layout only.

Visualization Summary

Parameter	Value
Conduit	1 1/4" EMT
Wire Count	4
Total Wire Area	0.3048 in ²
Conduit Area	1.4957 in ²
Fill Percentage	20.4%
Jam Status	OK

Appendix A: Ampacity Forensics

Step	Detail	Value	Code Reference
input parameters	Input parameters for ampacity calculation	Parameters validated	NEC 2020
rooftop correction	Rooftop sunlight temperature adder	+33°C adder applied	310.15(B)(2) • NEC 2020 310.15(B)(2)
Ambient Temperature Adjustment	Ambient temperature correction factor lookup	0.58	Table 310.15(B)(1) - 90°C Column • Based on NEC 2020 Table 310.15(B)(1)
Adjustment for Number of Current-Carrying Conductors	Conductor bundling adjustment factor	0.8	Table 310.15(C)(1) • Based on NEC 2020 Table 310.15(C)(1)
total derating	Combined derating factor calculation	0.46399999999999997	—
Required Load Ampacity	Calculate required ampacity for load	62.50A	—
Base Ampacity Lookup	Base ampacity for 3 AWG Copper at 90°C	115A	Table 310.16 • Based on NEC 2020 Table 310.16
Derated Ampacity	Apply derating factors to base ampacity	53.36A	—
Terminal Rating	Terminal temperature rating limit check	Not limited (53.36A < 100A)	Table 310.16 • Based on NEC 2020 110.14(C)
final ampacity	Final allowable ampacity	53.36A	—
wire selection	Recommended wire size selection	3 AWG	—

Appendix B: Voltage Drop & Conduit Fill Forensics

Voltage Drop Steps

Step	Detail	Value	Code Reference
Resistance Lookup	DC resistance per 1000 ft for 3 AWG	Per Table	Ch. 9 Tables 8 & 9
Effective Length Used	Circuit distance applied to calculation	250 ft	User Input
Load Current	Current draw considered for voltage drop	50A	User Input
Formula Substitution	$V_d = K \times I \times (R \times \cos\theta + X \times \sin\theta) \times L / 1000$	5.22 V	Calculated
Final % Drop	Percentage drop at the load	2.51%	Calculated

Conduit Fill Steps

Step	Detail	Value	Code Reference
Wire Area Lookup (Table 5)	Individual area for THHN	0.0762 in ²	Ch. 9 Table 5
Total Wire Area	4 wires × individual area	0.3048 in ²	Calculated
Conduit Area (Table 4)	1 1/4" EMT internal area	1.4957 in ²	Ch. 9 Table 4
Fill % Calculation	$\text{Fill \%} = (\text{Wire Area} \div \text{Conduit Area}) \times 100$	20.4%	Calculated
Max Fill Check (40%)	Compare against NEC maximum	Pass	Ch. 9 Table 1

Appendix C: Citations & Verification

NEC References

NEC 2020 110.14(C)
NEC 2020 Ch.9 Table 5
NEC 2020 Ch.9 Table 8
NEC 2020 Ch.9 Table 9
NEC 2020 Ch.9 Tables 4 & 5
NEC 2020 Table 310.15(B)(1)
NEC 2020 Table 310.15(C)(1)
NEC 2020 Table 310.16
NEC 310.15(B)(2) - Rooftop Temperature Adjustment

Verification

Field	Value
Export ID	CL-20251219-BFPV7d
SHA-256 Checksum	6641efe1796b588a512291fd123b2bd41dda87e34246c61f1169edba572150c6
Generated	2025-12-19T14:04:12.273Z
Code Edition	NEC 2020
Project	ConduitLab Sample Project
Checksum Purpose	Ensures report integrity; matches exported data snapshot.

Appendix D: Machine-Readable Data & Legal

Project Data (JSON)

```
{
  "loadAmps": "50",
  "material": "Cu",
  "selectedWire": null,
  "calculatedWire": "3 AWG",
  "ambientTemp": 35,
  "conductors": 5,
  "isContinuous": true,
  "insulationType": "90",
  "insulationTypeValue": "THHN",
  "wetLocation": false,
  "terminalTemp": "75",
  "rooftopExposure": true,
  "rooftopHeight": 0.5,
  "isRooftop": true,
  "rooftopAdderC": 33,
  "ambientEffectiveC": 68,
  "voltage": 208,
  "phase": "3",
  "distance": "250",
  "powerFactor": "0.9",
  "conduit": "PVC",
  "vdMethod": "exact",
  "vdLengthSemantics": "one-way",
  "conduitType": "EMT",
  "conduitSize": "11/4\"",
  "voltageDropData": {
    "dropVolts": 5.22,
    "dropPercent": 2.51,
    "voltageAtLoad": 202.78
  },
  "conduitFillData": {
    "fillPercent": 20.4,
    "maxFillPercent": 40,
    "wireCount": 4,
    "jammedWireCount": 0,
    "visualJamDetected": false
  }
}
```

THE CALCULATIONS AND INFORMATION PROVIDED BY CONDUITLAB ARE FOR REFERENCE AND DOCUMENTATION PURPOSES ONLY AND DO NOT CONSTITUTE ENGINEERING, DESIGN, OR CODE-COMPLIANCE CERTIFICATION. ALL RESULTS ARE PROVIDED "AS IS," WITHOUT ANY WARRANTIES OF ANY KIND. TELEIOS AI, LLC AND CONDUITLAB DISCLAIM ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ACCURACY, COMPLETENESS, COMPLIANCE WITH NEC, CEC, IEC, OR ANY OTHER ELECTRICAL STANDARD, OR FITNESS FOR A PARTICULAR PURPOSE. USERS RETAIN FULL RESPONSIBILITY FOR VERIFYING ALL CALCULATIONS, SELECTIONS, AND INSTALLATIONS, AND FOR ENSURING COMPLIANCE WITH ALL APPLICABLE CODES AND AUTHORITY-HAVING-JURISDICTION REQUIREMENTS. CONDUITLAB DOES NOT PERFORM PROFESSIONAL ENGINEERING SERVICES AND DOES NOT ASSUME RESPONSIBILITY FOR ANY DECISIONS MADE OR ACTIONS TAKEN BASED ON THIS SOFTWARE OR THE REPORTS IT GENERATES. IN NO EVENT SHALL TELEIOS AI, LLC OR CONDUITLAB BE LIABLE FOR ANY DAMAGES ARISING FROM THE USE OF THIS SOFTWARE OR ITS OUTPUTS.